

Saxon



Unit 11 Mercers Road, Bury St Edmunds,
Suffolk IP32 7HX

CERTIFICATE OF INSPECTION

This is to certificate the maintenance of Portable Fire Extinguishers has been carried out this day as required by the British Standards code of practice BS5306 Part 3.

Customer Name: BRADFELD PARK CAMPSITE

Location: IXER LANE, BRADFELD COMBUST
BURY ST EDMUNDS, SUFFOLK, IP30 0LR

Engineers Name/Signature: STEVE GRIMMER, SL

Date of Issue: 17-07-2025

Expiry Date: JULY 2026

Monthly or at least quarterly inspection of all extinguishers should be carried out by the user or the users representative, this ensures that appliances are in their proper position and have not been discharged, lost pressure or suffered obvious damage.

member of



Registered Office: 11 Mercers Road, Bury St Edmunds, Suffolk IP32 7HX
Company Reg No: 07201217